



RFB Addendum # 01

RFB Title: SouthWest Transit Bus Wash

RFB Number: RFB# 26-0002

Addendum Issue Date: 05-21-2026

Purpose

The Request for Bid (RFB) for the above referenced project is modified as set forth in this Addendum. The original RFB Documents remain in full force and effect, except as modified by this Addendum, which is hereby made part of this RFB. Bidder shall take this Addendum into consideration when preparing and submitting its proposal.

Changes to the RFB

2. MODIFICATIONS TO SPECIFICATIONS (ATTACHMENT H)

Section 3 – Technical Specifications

Final Rinse Spray Arch (Section 3.6)

DELETE:

“Each spray pipe shall be constructed of Schedule 40 galvanized pipe...”

REPLACE WITH:

“Each spray pipe, including the RO final rinse manifold, supporting braces, and all structural components of the RO rinse arch, shall be constructed of stainless steel.”

3. CLARIFICATIONS

This change is issued in response to vendor questions and supersedes any conflicting requirements in the original RFB documents.

4. ACKNOWLEDGMENT

Bidders must acknowledge receipt of this Addendum in their bid submission.

Proposal Instructions

Bidders are required to acknowledge this Addendum and incorporate the updated information into their proposal submissions.

Issued By:

Name: Jacob Bruns

Title: Procurement Specialist

Organization: SouthWest Transit